



RAdata, LLC  
27 Ironia Road, Unit 2  
Flanders, NJ 07836  
973-927-7303 Phone  
973-927-4980 Fax

**Customer:** Cerebral Palsy  
61 Myrtle Street  
Cranford, NJ 070160000

## Laboratory Results

**Sample Number**      **Sample Location**      **Collected By**  
0421-9245      75 Rod Smith Place - Cranford Twp      Richard, Hand

| Sample No.  | Collected                                             | Analyzed             | Parameter       | Result      | MCL #    | Method           |
|-------------|-------------------------------------------------------|----------------------|-----------------|-------------|----------|------------------|
| 0421-9245   | 4/10/2021 9:28:00 AM<br>Staff Room Sink               | 4/15/2021 8:53:00 AM | Lead (1st Draw) | < 2.00 ug/l | 15 ug/L  | Std Method 3113B |
| 0421-9245   | 4/10/2021 9:28:00 AM<br>Staff Room Sink               | 4/16/2021 9:10:00 AM | Copper          | 0.467 mg/l  | 1.3 mg/L | Std Method 3111B |
| 0421-9245-2 | 4/10/2021 9:33:00 AM<br>Therapy Kitchen Sink          | 4/15/2021 8:53:00 AM | Lead (1st Draw) | < 2.00 ug/l | 15 ug/L  | Std Method 3113B |
| 0421-9245-2 | 4/10/2021 9:33:00 AM<br>Therapy Kitchen Sink          | 4/16/2021 9:10:00 AM | Copper          | 0.442 mg/l  | 1.3 mg/L | Std Method 3111B |
| 0421-9245-3 | 4/10/2021 9:35:00 AM<br>Therapy Office Sink           | 4/15/2021 8:53:00 AM | Lead (1st Draw) | < 2.00 ug/l | 15 ug/L  | Std Method 3113B |
| 0421-9245-3 | 4/10/2021 9:35:00 AM<br>Therapy Office Sink           | 4/16/2021 9:10:00 AM | Copper          | 0.700 mg/l  | 1.3 mg/L | Std Method 3111B |
| 0421-9245-4 | 4/10/2021 9:40:00 AM<br>Apartment Room Food Prep Sink | 4/15/2021 8:53:00 AM | Lead (1st Draw) | < 2.00 ug/l | 15 ug/L  | Std Method 3113B |
| 0421-9245-4 | 4/10/2021 9:40:00 AM<br>Apartment Room Food Prep Sink | 4/16/2021 9:10:00 AM | Copper          | 0.430 mg/l  | 1.3 mg/L | Std Method 3111B |
| 0421-9245-5 | 4/10/2021 9:44:00 AM<br>Cafeteria Sink                | 4/15/2021 8:53:00 AM | Lead (1st Draw) | < 2.00 ug/l | 15 ug/L  | Std Method 3113B |
| 0421-9245-5 | 4/10/2021 9:44:00 AM<br>Cafeteria Sink                | 4/16/2021 9:10:00 AM | Copper          | 0.517 mg/l  | 1.3 mg/L | Std Method 3111B |
| 0421-9245-6 | 4/10/2021 9:47:00 AM<br>Kitchen Food Prep Sink        | 4/15/2021 8:53:00 AM | Lead (1st Draw) | < 2.00 ug/l | 15 ug/L  | Std Method 3113B |
| 0421-9245-6 | 4/10/2021 9:47:00 AM<br>Kitchen Food Prep Sink        | 4/16/2021 9:10:00 AM | Copper          | 0.313 mg/l  | 1.3 mg/L | Std Method 3111B |
| 0421-9245-7 | 4/10/2021 9:48:00 AM<br>Kitchen Triple Sink           | 4/15/2021 8:53:00 AM | Lead (1st Draw) | < 2.00 ug/l | 15 ug/L  | Std Method 3113B |
| 0421-9245-7 | 4/10/2021 9:48:00 AM<br>Kitchen Triple Sink           | 4/16/2021 9:10:00 AM | Copper          | 0.334 mg/l  | 1.3 mg/L | Std Method 3111B |
| 0421-9245-8 | 4/10/2021 9:50:00 AM<br>Kitchen Handwash Sink         | 4/15/2021 8:53:00 AM | Lead (1st Draw) | < 2.00 ug/l | 15 ug/L  | Std Method 3113B |

# MCL - Maximum Contaminant Level

ND - Not Detected

\* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

\*\* If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, May 4, 2021

NJDEP Laboratory Certification # 14006

Page 1 of 4



RAdata, LLC  
27 Ironia Road, Unit 2  
Flanders, NJ 07836  
973-927-7303 Phone  
973-927-4980 Fax

**Customer:** Cerebral Palsy  
61 Myrtle Street  
Cranford, NJ 070160000

## Laboratory Results

| Sample Number | Sample Location                   | Collected By  |
|---------------|-----------------------------------|---------------|
| 0421-9245     | 75 Rod Smith Place - Cranford Twp | Richard, Hand |

| Sample No.  | Collected                                     | Analyzed             | Parameter | Result      | MCL #    | Method           |
|-------------|-----------------------------------------------|----------------------|-----------|-------------|----------|------------------|
| 0421-9245-8 | 4/10/2021 9:50:00 AM<br>Kitchen Handwash Sink | 4/16/2021 9:10:00 AM | Copper    | 0.961 mg/l  | 1.3 mg/L | Std Method 3111B |
| 0421-9245-9 | 4/10/2021 9:56:00 AM<br>Nurses Office Sink    | 4/15/2021 8:53:00 AM | Lead      | < 2.00 ug/l | 5 ug/l   | Std Method 3113B |
| 0421-9245-9 | 4/10/2021 9:56:00 AM<br>Nurses Office Sink    | 4/16/2021 9:10:00 AM | Copper    | 0.361 mg/l  | 1.3 mg/L | Std Method 3111B |

# MCL - Maximum Contaminant Level

ND - Not Detected

\* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

\*\* If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, May 4, 2021

NJDEP Laboratory Certification # 14006

Page 2 of 4